



COMMERCIAL USER PRETREATMENT APPLICATION REQUIREMENTS

1. Provide a completed Commercial User Pretreatment Application for each tenant unit.
2. Provide a floor plan showing all fixtures and building sewer.
3. Provided a civil plan showing the site, all existing and proposed utilities (water, gas, sewer, electric, telephone and cable) and site specific item such as wells, septic system and walls. The civil plan must include a sewer profile and all related details.
4. The submission shall include stamped flow calculations.
5. If the tenant unit will have a process waste the users shall provide detailed information regarding the volume and nature of the waste stream. In addition information regarding the pretreatment equipment is required including grease interceptors, grease recovery devices, lint interceptors, oil/water separators, amalgam separators, silver recovery devices, hair interceptors, fur interceptors, etc...
6. Commercial Users with a process waste may require a separate application some examples are:
 - a. Food Service Facilities
 - b. Laundries, Laundromats and Dry Cleaners
 - c. Maintenance and Repair Facilities
 - d. Dentists
 - e. Medical Facilities
 - f. Barber, Hair Dressers
 - g. Pet Grooming Facilities
 - h. Any facility that may use or store hazardous materials such as oils, flammables, toxics and corrosives.